

Wadsworth Atheneum Historic Lighting Fixtures



Work Scope:

- Clean/conservate existing finish to remove all dust and surface corrosion, lightly burnish and blend existing patina, including multiple applications of museum grade wax.
- Replace and rewire all electrical components with UL listed products and test in accordance with UL standards. Medium base sockets to be utilized.
- Clean clear glass globe to remove any surface residue
- No replacement glass.
- Power conductors shall be concealed in a black acrylic coated fiberglass sleeve woven through the chain.
- Fabricate a patina matching brass socket cover.

Approval: _____ Date: _____

GRAND LIGHT

Historic Lighting Restoration & Custom Lighting

104 Day St. Seymour, Ct 06483

PH: 1-800-922-1469 Fax: 203-828-6307

Web: LightRestoration.com

Project: Wadsworth Atheneum

Lamp: 1. medium base

Ballast: N/A

Voltage: 120v

Finish: Statuary Bronze

QTY: 2

Date: 10/7/14

Type: WL24