

**Mammoth Hot Springs Hotel Rehabilitation
Yellowstone National Park
Type: H3**



(Pre-Restoration)

Description: Flush Mount

Dimensions: 6" x 6"

Location: Mammoth Hot Springs Hotel

Lights: 1

Work Scope:

- Clean and conserve existing finish with application of museum grade wax.
- Replace and rewire all electrical components with UL listed products and test in accordance with UL standards. Medium base socket to be utilized.
- Provide 2' leads.
- Repair all minor mechanical defects.
- (1) fixture has a previous repair. This area will be cleaned of excess epoxy.

GRAND LIGHT

Historic Lighting Restoration & Custom Lighting

104 Day St. Seymour, Ct 06483

PH: 1-800-922-1469 Fax: 203-785-1184

Web: LightRestoration.com

Project: Mammoth Hot Springs

Lamp: Incandescent

Socket: Med Base

S/O #: TBD

Finish: TBD

Ballast: N/A

Glass: N/A

Voltage: 120v

Circuits: 1

Type: Indoor/Dry

QTY: 3

Date: 1/19/17

Type: H3